

# CERTIFICATE

## of Conformity

**Registration No.:** AK 50662214 0001  
**Report No.:** CN24RJL3 002  
**Holder:** Shenzhen Elecod Electric Co.,Ltd.  
Room 320, 3rd Floor, Building C, Bantian International  
Center, No. 5 Huancheng South Road  
Ma An Tang Community, Bantian Street,  
Longgang District, Shenzhen,  
Guangdong  
P.R. China  
**Product:** Converter  
(Energy Storage Converter)

### Type designation listed on the next page

The certificate of conformity refers to the above-mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned on the next page. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

### Certification Body

**Date:** 2025-01-20



A. Chen



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

# CERTIFICATE

## of Conformity

**Registration No.:** AK 50662214 0001

**Product:** Converter  
(Energy Storage Converter)

**Tested according to:** EN 50549-1:2019

**Identification:** Type Designation  
Monet-50AC, Monet-62.5AC, Monet-100AC

Firmware version: V3.39.1

Compliant to :  
-Requirements to Type A Generation Units.  
-COMMISSION REGULATION(EU) 2016/631(RfG).

Remarks:  
Conjunction with the Netherlands national grid code.  
The PCE(3P4W) to grid isolated and control redundant  
shall be equipped in final installation.  
Refer to test report CN24RJL3 002 for details.



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**